

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:213 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model "Fireworks" FW2 and FW4 System Control Computer. Consists of the main PC with several required peripherals. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FW2, FW4, FW2UL2, FW4UL2	System Control Computer
PCWD, PCWDSW (factory installed)	Computer Card
FW-PP	Parallel port expander card
FW-SND	Sound card
FW-HD	Second hard drive
FW-MOD	Modem card
FW-SP	Serial port expander card
FW-ZIP	Internal zip drive
FW-VIDVC	PCI Video Card
FW-VIDVC2	AGP Video Card
FW-VIDTVC	PCI TV Video Card for CCTV
APS or BPS	Power Supply
PCCA	Computer Mounting Hardware
Mini-Mux, FCOM-FIB, and MEGA Buffer	Printed Circuit Boards
FW-19MN, -19MNTS, -19MON, -19MONTs,	Monitors
FW-21MN, -21MNTS, -21MON, P260	

RATING: 120/240 VAC 50/60Hz

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as system control computer for use with listee's separately listed Models EST-3 (CSFM Listing No. 7165-1591:186 & 7170-1591:187), EST-2 (CSFM Listing No. 7170-1591:195), IRC-3 (CSFM Listing No. 7165-1591:147 & 7170-1591:157) and FCC (CSFM Listing No. 7165-1591:139 & 7170-1591:158) fire alarm control units.

NOTE: Formerly 7300-1388:247

11-02-2002



information sources.

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable

Date Issued:

JUNE 17, 2003

Listing Expires June 30, 2004

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager